

Incident Report

Legacy Way – Exceedance of Total Nitrogen



1. Summary of Event

On the 9 December 2021 Transurban received interim laboratory results from SAS Laboratories indicating that the Legacy Way Water Treatment Plant discharge water quality monitoring results for samples taken on Thursday 2 December recorded an exceedance for Total Nitrogen as per the table below:

	Water Quality Discharge Limit	Laboratory Results
Total Nitrogen	2.1mg/L	3.2mg/L

2. Immediate Actions Taken

Transurban have taken the following actions following identification of the event:

- Resampling of the water treatment plant discharge to assess if a sustained exceedance is occurring. Results of this sampling have not yet been received.
- The Department of Environment and Science and the Coordinator General were notified of the event.
- An investigation team was established.