

Ventilation Outlet Notification and Report

Ventilation Outlet Monitoring Notification

Notification of Ventilation Outlet above-limit reading WestConnex M4 East To be notified immediately to Project Company and RMS. Project Company is to notify DPE, EPA and NSW Health immediately	
Date	7 May 2020
Time (start and finish)	18:00 – 19:00
Relevant location	<input type="checkbox"/> Western Ventilation Facility <input checked="" type="checkbox"/> Eastern Ventilation Facility
Relevant limit	<input type="checkbox"/> Solid particles – 1 hour averaging period <input checked="" type="checkbox"/> NO ₂ or NO or both, as NO ₂ equivalent – 1 hour block averaging period <input type="checkbox"/> NO ₂ – 1 hour block averaging period <input type="checkbox"/> CO – 1 hour rolling averaging period <input type="checkbox"/> VOC – 1 hour rolling averaging period
Above-limit reading Detail the above-limit reading that was received	NO ₂ or NO or both, as NO ₂ equivalent – 1 hour block average result of 30.9 mg/m ³
Duration Detail the duration of the above-limit reading or event	1 hour
Nature of event Detail nature of the event that contributed to the above- limit reading	Initial indications show that the above-limit reading was the result of routine maintenance that had uploaded calibration data to both the operational management control system and further onto the Linkt website.
Was the data valid? If unknown at this stage, please indicate.	No.
Was there an emergency? Refer section 6.5 of this Plan. If this is unknown at this stage, please indicate.	No.
Measures employed Detail measures employed to minimise the concentration levels	None.
Commitment to prepare and submit a Report on Above-Goal Reading A Report on Above-Goal Reading will be prepared for this notification. Please note that a Report is not required in the event of an emergency.	
Person responsible for notification	Name: Peter Redwin
	Position: Head of Operations and Maintenance
	Organisation: WestConnex Transurban