

# Ventilation Outlet Notification and Report

## Ventilation Outlet Monitoring Notification

<b>Notification of Ventilation Outlet above-limit reading</b> WestConnex M8	
To be notified immediately to Project Company and TfNSW. Project Company is to notify DPE, EPA and NSW Health within 24 hours.	
<b>Date</b>	05 July 2020
<b>Time</b> (start and finish)	10:00 – 12:00
<b>Relevant location</b>	<input checked="" type="checkbox"/> Kingsgrove Ventilation Facility <input type="checkbox"/> Arncliffe Ventilation Facility <input type="checkbox"/> St Peters Ventilation Facility
<b>Relevant limit</b>	<input checked="" type="checkbox"/> Solid particles – 1-hour average of 1.1 mg/m <sup>3</sup> <input type="checkbox"/> NO <sub>2</sub> or NO or both, as NO <sub>2</sub> equivalent – 1-hour average block of 20 mg/m <sup>3</sup> <input type="checkbox"/> NO <sub>2</sub> – 1-hour block average of 2.0 mg/m <sup>3</sup> <input type="checkbox"/> CO – 1-hour rolling average of 40 mg/m <sup>3</sup> <input type="checkbox"/> VOC – 1-hour rolling average of 4.0 mg/m <sup>3</sup>
<b>Above-limit reading</b> Detail the above-limit reading that was received	Kingsgrove Ventilation Facility – 1.115 mg/ m <sup>3</sup>
<b>Duration</b> Detail the duration of the above-limit reading or event	2 hrs
<b>Nature of event</b> Detail nature of the event that contributed to the above- limit reading	Undetermined at this stage. Preliminary investigations are currently underway.
<b>Was the data valid?</b> If unknown at this stage, please indicate.	Yes.
<b>Was there an emergency?</b> Refer section 6.5 of this Plan. If this is unknown at this stage, please indicate.	No.
<b>Measures employed</b> Detail measures employed to minimise the concentration levels	Ventilation systems were allowed to autonomously respond.
<b>Commitment to prepare and submit a Report on Above-Goal Reading</b> A Report on Above-Goal Reading will be prepared for this notification. Please note that a Report is not required in the event of an emergency.	
<b>Person responsible for notification</b>	Name: Peter Redwin
	Position: Head of Operations and Maintenance
	Organisation: WestConnex Transurban