

Environmental Protection Licence Monitoring Data

Project Name:

Licensee:

Monitoring Period:

Website:

Environmental Protection Licence:

Premise Address:

Discharge/Monitoring Point:

Sampling Method:

WestConnex - M8

WCX M5 PT PTY LTD

November 2025

www.westconnex.com.au/NewM5Environment

21351

Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205

M8 Water Treatment Plant

Grab Sample



	General				Metals (µg/L)										Total Recoverable Hydrocarbons						
Date	pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40		Compliant
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
5/11/2025	6.5 - 8.5	7.11	25	5.20	600	60	8.0	1.0	10.3	1.0	10600	783	150	5.0	<100	<100	<100	<100	<100	<100	Yes

*100th percentile concentration limit specified by EPL 21351