

Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M8
Licensee: WCX M5 PT PTY LTD
Monitoring Period: December 2025
Website: www.westconnex.com.au/NewM5Environment
Environmental Protection Licence: 21351
Premise Address: Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205
Discharge/Monitoring Point: M8 Water Treatment Plant
Sampling Method: Grab Sample



	General				Metals (µg/L)										Total Recoverable Hydrocarbons						
Date	pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40		Compliant
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
2/12/2025	6.5 - 8.5	7.03	25	6.20	600	50	8.0	1.0	10.3	1.0	10600	712	150	5.0	<100	<100	<100	<100	<100	<100	Yes

*100th percentile concentration limit specified by EPL 21351