

Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M8
Licensee: WCX M5 PT PTY LTD
Monitoring Period: January 2026
Website: www.westconnex.com.au/NewM5Environment
Environmental Protection Licence: 21351
Premise Address: Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205
Discharge/Monitoring Point: M8 Water Treatment Plant
Sampling Method: Grab Sample



Date	General				Metals (µg/L)								Total Recoverable Hydrocarbons						Compliant		
	pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34			C34-C40	
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result		Limit*	Result
16/01/2026	6.5 - 8.5	7.19	25	5.80	600	40	8.0	1.0	10.3	1.0	10600	559	150	5.0	<100	<100	<100	<100	<100	<100	Yes

*100th percentile concentration limit specified by EPL 21351