

Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M4-M8 LINK
Licensee: WCX M4-M5 PT PTY LTD
Monitoring Period: March 2026
Website: www.westconnex.com.au/environment/environmental-documents
Environmental Protection Licence: 21616
Premise Address: ST PETERS INTERCHANGE - M4-M5 LINK TUNNELS PROJECT, 16 ALBERT ST, ST PETERS NSW 2044
Discharge/Monitoring Point: Water Treatment Plant ARN-2
Sampling Method: Grab Sample



General				Metals (mg/L)																Hydrocarbon (mg/L)		Nutrients (mg/L)		Compliant	
Date	pH		Turbidity (NTU)		Cadmium		Chromium (VI)		Iron		Lead		Manganese		Mercury		Nickel		Zinc		Benzene		Ammonia		YES/NO
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
10/3/2026	7.0 - 8.5	7.44	10	0.7	0.0007	-	0.006	-	0.3	-	0.0044	-	1.90	-	0.0001	-	0.07	-	0.015	-	0.5	-	0.91	0.08	YES
24/03/2026	7.0 - 8.5	8.13	10	0.2	0.0007	0.0001	0.006	0.006	0.3	0.05	0.0044	0.001	1.90	0.001	0.0001	0.00004	0.07	0.001	0.015	0.005	0.5	0.001	0.91	0.05	YES

* 100th percentile concentration limit

Discharge Flow Data		
Daily discharge limit: 2,400kL		
Date	Daily Flow (kL)	Compliant
01/03/2026	749.59	Yes
02/03/2026	700.57	Yes
03/03/2026	768.31	Yes
04/03/2026	686.00	Yes
05/03/2026	729.90	Yes
06/03/2026	713.81	Yes
07/03/2026	705.87	Yes
08/03/2026	811.35	Yes
09/03/2026	760.67	Yes
10/03/2026	733.77	Yes
11/03/2026	762.95	Yes
12/03/2026	714.17	Yes
13/03/2026	729.63	Yes
14/03/2026	737.29	Yes
15/03/2026	736.92	Yes
16/03/2026	741.63	Yes
17/03/2026	789.06	Yes
18/03/2026	938.60	Yes
19/03/2026	976.83	Yes
20/03/2026	801.53	Yes
21/03/2026	837.22	Yes
22/03/2026	748.78	Yes
23/03/2026	751.09	Yes
24/03/2026	706.29	Yes
25/03/2026	780.48	Yes
26/03/2026	527.34	Yes
27/03/2026	1681.68	Yes
28/03/2026	809.38	Yes
29/03/2026	833.38	Yes
30/03/2026	857.38	Yes
31/03/2026	881.38	Yes