

Environmental Protection Licence Monitoring Data

**Project Name:** WestConnex - M8  
**Licensee:** WCX M5 PT PTY LTD  
**Monitoring Period:** March 2026  
**Website:** [www.westconnex.com.au/NewM5Environment](http://www.westconnex.com.au/NewM5Environment)  
**Environmental Protection Licence:** 21351  
**Premise Address:** Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205  
**Discharge/Monitoring Point:** M8 Water Treatment Plant  
**Sampling Method:** Grab Sample



|          | General   |         |                 |         | Metals (µg/L) |        |        |        |        |        |           |        |        |        | Total Recoverable Hydrocarbons |        |         |        |         |        |           |
|----------|-----------|---------|-----------------|---------|---------------|--------|--------|--------|--------|--------|-----------|--------|--------|--------|--------------------------------|--------|---------|--------|---------|--------|-----------|
| Date     | pH        |         | Turbidity (NTU) |         | Aluminium     |        | Cobalt |        | Copper |        | Manganese |        | Zinc   |        | C10-C16                        |        | C16-C34 |        | C34-C40 |        | Compliant |
|          | Limit     | Results | Limit           | Results | Limit*        | Result | Limit* | Result | Limit* | Result | Limit*    | Result | Limit* | Result | Limit*                         | Result | Limit*  | Result | Limit*  | Result |           |
| 3/3/2026 | 6.5 - 8.5 | 7.31    | 25              | 3.50    | 600           | 60     | 8.0    | 1.0    | 10.3   | 1.0    | 10600     | 724    | 150    | 6.0    | <100                           | <100   | <100    | <100   | <100    | <100   | Yes       |

\*100th percentile concentration limit specified by EPL 21351