

Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M8
Licensee: WCX M5 PT PTY LTD
Monitoring Period: September 2026
Website: <https://www.linkt.com.au/using-toll-roads/about-sydney-toll-roads/westconnex/westconnex-m8/water-quality/sydney>
Environmental Protection Licence: 21351
Premise Address: Operational Water Treatment Plant M8 - Motorway Operations Complex 3 Arncliffe NSW 2205
Discharge/Monitoring Point: M8 Water Treatment Plant
Sampling Method: Grab Sample



	General				Metals (µg/L)										Total Recoverable Hydrocarbons						
Date	pH		Turbidity (NTU)		Aluminium		Cobalt		Copper		Manganese		Zinc		C10-C16		C16-C34		C34-C40		Compliant
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
1/9/2026	6.5 - 8.5	8.06	25	3.00	600	100	8.0	1.0	10.3	1.0	10600	614	150	5.0	<100	<100	<100	<100	<100	<100	Yes

*100th percentile concentration limit specified by EPL 21351