

Environmental Protection Licence Monitoring Data



Project Name:
Licensee:
Monitoring Period:
Website:
Environmental Protection Licence:
Premise Address:
Discharge/Monitoring Point:
Sampling Method:

WestConnex - M4-M8 LINK
WCX M4-M5 PT PTY LTD
September 2026
<https://www.linkt.com.au/using-toll-roads/about-sydney-toll-roads/westconnex/westconnex-rozelle-interchange/water-quality/sydney>
21616
ST PETERS INTERCHANGE - M4-M5 LINK TUNNELS PROJECT, 16 ALBERT ST, ST PETERS NSW 2044
Water Treatment Plant ARN-2
Grab Sample

General					Metals (mg/L)																Hydrocarbon (mg/L)		Nutrients (mg/L)		Compliant
Date	pH		Turbidity (NTU)		Cadmium		Chromium (VI)		Iron		Lead		Manganese		Mercury		Nickel		Zinc		Benzene		Ammonia		YES/NO
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
2/9/2026	7.0 - 8.5	7.05	10	0.1	0.0007	0.0001	0.006	0.006	0.3	0.05	0.0044	0.001	1.90	0.001	0.0001	0.00004	0.07	0.002	0.015	0.009	0.5	0.001	0.91	0.03	YES
18/9/2026	7.0 - 8.5	7.12	10	-	0.0007	-	0.006	-	0.3	-	0.0044	-	1.90	-	0.0001	-	0.07	-	0.015	-	0.5	-	0.91	0.03	YES

* 100th percentile concentration limit

Discharge Flow Data		
Daily discharge limit: 2,400kL		
Date	Daily Flow (kL)	Compliant
01/09/2026	636.32	Yes
02/09/2026	650.02	Yes
03/09/2026	721.21	Yes
04/09/2026	715.62	Yes
05/09/2026	692.01	Yes
06/09/2026	692.99	Yes
07/09/2026	627.91	Yes
08/09/2026	741.94	Yes
09/09/2026	711.55	Yes
10/09/2026	659.72	Yes
11/09/2026	764.33	Yes
12/09/2026	679.51	Yes
13/09/2026	753.56	Yes
14/09/2026	658.90	Yes
15/09/2026	554.48	Yes
16/09/2026	721.14	Yes
17/09/2026	693.43	Yes
18/09/2026	647.15	Yes
19/09/2026	653.16	Yes
20/09/2026	656.80	Yes
21/09/2026	680.12	Yes
22/09/2026	733.81	Yes
23/09/2026	627.35	Yes
24/09/2026	743.76	Yes
25/09/2026	801.13	Yes
26/09/2026	667.22	Yes
27/09/2026	710.10	Yes
28/09/2026	669.61	Yes
29/09/2026	686.75	Yes
30/09/2026	629.09	Yes