Environmental Protection Licence Monitoring Data

Project Name: WestConnex - M4-M8 LINK
Licensee: WCX M4-M5 PT PTY LTD
Monitoring Period: October 2026
Website: https://www.linkt.com.au/using-toll-roads/about-sydney-toll-roads/westconnex/westconnex-rozelle-interchange/water-quality/sydney
Environmental Protection Licence: 21616
Premise Address: ST PETERS INTERCHANGE - M4-M5 LINK TUNNELS PROJECT, 16 ALBERT ST, ST PETERS NSW 2044
Discharge/Monitoring Point: Water Treatment Plant ARN-2
Sampling Method: Grab Sample

	General				Metals (mg/L)																Hydrocarbon (mg/L)		Nutrients (mg/L)		Compliant
Date	pH		Turbidity (NTU)		Cadmium		Chromium (VI)		Iron		Lead		Manganese		Mercury		Nickel		Zinc		Benzene		Ammonia		YES/NO
	Limit	Results	Limit	Results	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	Limit*	Result	
8/10/2026	7.0 - 8.5	7.15	10	0.1	0.0007	0.0001	0.006	0.005	0.3	0.05	0.0044	0.001	1.90	0.001	0.0001	0.00004	0.07	0.001	0.015	0.005	0.5	0.001	0.91	0.10	YES
21/10/2026	7.0 - 8.5	7.16	10	-	0.0007	-	0.006	-	0.3	-	0.0044	-	1.90	-	0.0001	-	0.07	-	0.015	-	0.5	-	0.91	0.02	YES

* 100th percentile concentration limit

Discharge Flow Data
Daily discharge limit: 2,400kL

Date	Daily Flow (kL)	Compliant
01/10/2026	652.53	Yes
02/10/2026	708.14	Yes
03/10/2026	740.77	Yes
04/10/2026	842.15	Yes
05/10/2026	670.39	Yes
06/10/2026	714.62	Yes
07/10/2026	647.78	Yes
08/10/2026	648.16	Yes
09/10/2026	724.87	Yes
10/10/2026	665.16	Yes
11/10/2026	743.55	Yes
12/10/2026	651.59	Yes
13/10/2026	716.07	Yes
14/10/2026	879.56	Yes
15/10/2026	941.10	Yes
16/10/2026	1026.33	Yes
17/10/2026	636.17	Yes
18/10/2026	903.86	Yes
19/10/2026	1069.59	Yes
20/10/2026	838.37	Yes
21/10/2026	708.13	Yes
22/10/2026	709.50	Yes
23/10/2026	675.51	Yes
24/10/2026	731.73	Yes
25/10/2026	707.47	Yes
26/10/2026	800.77	Yes
27/10/2026	724.20	Yes
28/10/2026	729.90	Yes
29/10/2026	788.04	Yes
30/10/2026	879.30	Yes
31/10/2026	937.60	Yes

Data sensitivity - Internal